

Product PI Number 180700130373 / GEN180711111508

Summary

| | | |
|-----------|------------------------------------|---|
| [PROD 12] | Product name (English) | Dual-Purpose Nozzle |
| [GEN 02] | Status | Subject of an appeal |
| [GEN 03] | Compliance | Not Compliant |
| [GEN 51] | Defect safety risks classification | |
| [GEN 08] | Processing Authority | Bundesamt für Seeschifffahrt und Hydrographie |
| [GEN 10] | Date of Creation | 11/07/2018 |

General

| | | |
|----------|-------------------------|--|
| [GEN 04] | Notifying member State | Germany |
| [GEN 05] | Notifying Authority | Bundesamt für Seeschifffahrt und Hydrographie Bernhard-Nocht-Str., 78 20359 Hamburg Phone: +49 40 3190 7100 Fax: +49 40 3190 5000 marktueberwachung@bsh.de www.bsh.de |
| [GEN 06] | Notifying Contact | Hendrik ROHDE Phone: +49-40-31907115 hendrik.rohde@bsh.de Fax: +49-40-31905000 |
| [GEN 07] | Processing Member State | Germany |
| [GEN 08] | Processing Authority | Bundesamt für Seeschifffahrt und Hydrographie Bernhard-Nocht-Str., 78 20359 Hamburg Phone: +49 40 3190 7100 Fax: +49 40 3190 5000 marktueberwachung@bsh.de www.bsh.de |
| [GEN 09] | Processor | Hendrik ROHDE Phone: +49-40-31907115 Fax: +49-40-31905000 hendrik.rohde@bsh.de |
| [GEN 10] | Date of Creation | 11/07/2018 |

Product


[GEN 12] Serial no. Batch 301506, 301510

[GEN 13] Year of manufacturing 2015

[GEN 14] Type of energy used

[GEN 15] Photo or drawing of product / packaging

[GEN 16] Photo of identification markings



[GEN 17] Additional Information

Economic operators

[GEN 18] Manufacturer/authorised representative(s)

[GEN 19] Importer(s) into the EEA

[GEN 20] Distributor(s)

[GEN 21] also distributed in

[GEN 22] Additional distributors

[GEN 23] User(s)

Standards

| | | |
|----------|---------------------------------------|------------------------------------|
| [GEN 24] | Investigated Directives / regulations | 1. Marine Equipment Directive |
| [GEN 25] | Standard applied by the manufacturer | EN 15182-3, wrong testing standard |

Conformity

| | | |
|----------|--|---|
| [GEN 26] | Is there a CE marking? | Wheelmarked |
| [GEN 27] | CE Marking (objections) | |
| [GEN 28] | Comments | <ul style="list-style-type: none">- wrong testing standard (EN 15182-3) applied- not able to pass 60 bar hydrostatic pressure test (as described EN 15182-2 and En 15182-3)- not able to pass the 25,5 bar pressure tightness test (as described EN 15182-2 and En 15182-3) |
| [GEN 29] | Declaration of Conformity available | Declaration of Conformity exists |
| [GEN 30] | Declaration of Conformity (documents) | 32a D.O.C.pdf |
| [GEN 31] | Declaration of Conformity (objections) | faulty |
| [GEN 32] | Comments | <ul style="list-style-type: none">- Notified Body for the issue of module B certificate not named and no number given- Notified Body for the issue of module D certificate not named and no number given |
| [GEN 33] | Method used to confirm compliance | 1. Marine Equipment Directive |
| [GEN 34] | Comments | |
| [GEN 35] | Declaration of Incorporation | Not Compliant |
| [GEN 36] | Declaration of Incorporation (objections) | |
| [GEN 37] | Comments | |
| [GEN 38] | ID number of Notified Body | 2198 |
| [GEN 39] | Address | KR Hellas 41, Athinas Av, Vogliagmeni GR-16671 GREECE, ATHENS |
| [GEN 40] | Additional required marks | |
| [GEN 41] | Additional required declarations | |
| [GEN 42] | Directive relevant documents, Instructions | |

Testing/Examination

| | | |
|----------|-------------------------|-----------|
| [GEN 43] | Test/Examination report | available |
|----------|-------------------------|-----------|

| | | |
|----------|--------------------------------------|---|
| [GEN 44] | Name / File ref. no. | IB 1554 and LW 007-17 (30.08.2017) |
| [GEN 45] | Test/examination date | 31/03/2016 |
| [GEN 46] | Test report(s) | |
| [GEN 47] | Test laboratory | TZW Prüfstelle Wasser Wasserwerkstr. 4 76137 Karlsruhe Germany Dr.-Ing. T. Bäumer Altensenner Weg 75 32052 Herford Germany |
| [GEN 48] | Scope of testing | 1.Safety relevant tests (pressure aspects) |
| [GEN 49] | Number of samples examined | 3 |
| [GEN 50] | Type of most serious injury possible | |
| [GEN 51] | Defect safety risks classification | |
| [GEN 52] | Description of health/safety defects | |

Accidents

| | | |
|----------|---------------------------------|--|
| [GEN 53] | Description of injury accidents | |
|----------|---------------------------------|--|

Measures

| | | |
|----------|---|---|
| [GEN 54] | Voluntary measures by the economic operator | |
| [GEN 55] | Enforcement measures taken by the authority | 1.Manufacturer/authorised representative(s) 1.Sales ban 2.Manufacturer/authorised representative(s) 2.Recall |
| [GEN 56] | Justification for the adopted measures | |
| [GEN 57] | Scope/Location of products affected | |
| [GEN 58] | Date of entry into force | |
| [GEN 59] | Duration | from 09 September 2016, Decision is subject of an appeal |
| [GEN 60] | Additional Information | |

Treatment

Treatment

[GEN 67] Baton to be passed to

[PROD 25] RAPEX No.

[GEN 62] Measure adopted

[GEN 63] Visibility of information for EU/EFTA authorities

[GEN 64] Internal documents

[GEN 65] Public documents